

CENTRAL MARIN FIRE DEPARTMENT



Developed by

Ruben Martin, Fire Marshal
Approved by

Scott Shurtz, Fire Chief

Fire Protection Standard 401

Fire Sprinkler Systems

Date: 8-21-2017

Revision: 8-21-2017

Page: 1 of 4

This Standard is promulgated pursuant to the Central Marin Fire Department amendments to the California Fire Code regarding the requirements for automatic fire sprinkler systems. For alarm monitoring requirements reference Central Marin Fire Department Standard 400.

I. Plans

- A. Plans shall be submitted as follows. At least three (3) sets of architectural or engineered blue line drawings shall be accompanied by three sets of calculations and material specification sheets for piping, fittings, and sprinkler heads.

II. One and Two Family Dwelling Units

- A. Buildings that are intended for occupancy as a one or two family dwelling unit shall have an automatic residential fire sprinkler system installed in accordance with most recent published edition of National Fire Protection Association Standard 13D with the following modifications:
1. Control valves and riser shall be installed as shown in Figure 1.
 2. A remote inspector test valve is required at the furthest remote portion of the system.
 3. Pilot heads shall be installed in the attic spaces directly above every attic access opening.
 4. All garages shall be sprinkled.
 5. A sprinkler head box shall be installed in every unit near the main sprinkler riser and shall include at least one head of each type installed, a sprinkler head wrench, and a water key to test the remote inspector test valve.
 6. A durable and permanent sign shall be installed at the test valve stating "Inspector Test Valve".

III. One and Two Family Dwellings Greater than 5,000 Square Feet

- A. Any Group R Division 3 Occupancy as defined by the California Building Code in excess of 5,000 square feet, shall have an automatic residential fire sprinkler system installed in accordance with most recent published edition of National Fire Protection Association Standard 13R with the following modifications:
1. A remote inspector test valve is required at the furthest remote portion of the system.
 2. Pilot heads shall be installed in the attic spaces directly above every attic access opening.

CENTRAL MARIN FIRE DEPARTMENT



Developed by

Ruben Martin, Fire Marshal
Approved by

Scott Shurtz, Fire Chief

Fire Protection Standard 401

Fire Sprinkler Systems

Date: 8-21-2017

Revision: 8-21-2017

Page: 2 of 4

3. All garages shall be sprinkled.
4. A sprinkler head box shall be installed in every building near the main sprinkler riser and shall include at least one head of each type installed, a sprinkler head wrench, and a water key to test the remote inspector test valve.
5. A durable and permanent sign shall be installed at the test valve stating "Inspector Test Valve".
6. The Fire Code Official will dictate the location of the FDC.

B. Any permissible reductions in fire flow stipulated by California Fire Code shall not be applied unless approved and the entire building is fully sprinkled. The Fire Code Official may approve such cases. In any case, the available fire flow shall not be less than 1,500 gallons per minute.

IV. Hotels/Motels and Apartment Buildings

A. Buildings that are intended for occupancy as a Group R-1 or R-2 Occupancy as defined by the California Building Code, shall have an automatic residential fire sprinkler system installed in accordance with the most recent published edition of National Fire Protection Association Standard 13R with the following modifications:

1. A remote inspector test valve is required at the furthest remote portion of the system.
2. Pilot heads shall be installed in the attic spaces directly above every attic access opening.
3. All garages shall be sprinkled in accordance with NFPA Std. 13 for Ordinary Hazard occupancies.
4. A sprinkler head box shall be installed in every building near the main sprinkler riser and shall include at least six heads of each type installed, a sprinkler head wrench, and a water key to test the remote inspector test valve.
5. A durable and permanent sign shall be installed at the test valve stating "Inspector Test Valve".
6. Fire Department will dictate the location of the FDC.

B. Any permissible reductions in fire flow stipulated by California Fire Code shall not be applied unless approved and the entire building is fully sprinkled in accordance with NFPA Std. 13. The Fire Code Official may approve such cases. In any case, the available fire flow shall not be less than 1,500 gallons per minute.

CENTRAL MARIN FIRE DEPARTMENT



Developed by

Ruben Martin, Fire Marshal

Approved by

Scott Shurtz, Fire Chief

Fire Protection Standard 401

Fire Sprinkler Systems

Date: 8-21-2017

Revision: 8-21-2017

Page: 3 of 4

V. All Commercial Structures

A. An automatic fire sprinkler system shall be installed in all of the following in accordance with the most recent published edition NFPA Std. 13:

VI. The following shall also have an automatic fire sprinkler system installed.

1. Every newly constructed, freestanding building or facility.
2. In newly created attached second dwelling units.
3. In all buildings which has more than fifty per cent (50%) floor area added or any "substantial remodel" as defined in this standard, within any 36-month period. The Chief may grant exceptions when alternate means of protection are installed as approved by the Chief.
4. In all buildings except R-3 occupancies, in excess of 3,000-sq. ft. which have more than ten per cent (10%) floor area added within any 36-month period. The Chief may grant exceptions when alternate means of protection are installed as approved by the Chief.
5. In all existing buildings, where fire sprinklers are required by provisions of this code, they shall be extended into all unprotected areas of the building in accordance with standards developed by the Chief.
6. All public storage facilities shall be provided with an automatic fire sprinkler system.

Exceptions:

1. Free standing Group U Occupancies not more than 1,000 square feet and provided with exterior wall and opening protection as per Table 5-A of the Building Code.
2. Agricultural buildings as defined in Appendix 3 of the Building Code and not exceeding 2,000 square feet, having clear unobstructed side yard of combustible materials, exceeding 60 feet in all directions and not exceeding 25 feet in height, and located within an Agricultural zoned district as defined in the Marin County Planning Code.
3. Any permissible reductions in fire flow stipulated by California Fire Code shall not be applied unless approved and the entire building is fully sprinkled in accordance with NFPA Std. 13. The Fire Code Official may approve such cases. In any case, the available fire flow shall not be less than 1,500 gallons per minute.

CENTRAL MARIN FIRE DEPARTMENT



Developed by
Ruben Martin, Fire Marshal
Approved by
Scott Shurtz, Fire Chief

Fire Protection Standard 401

Fire Sprinkler Systems

Date: 8-21-2017

Revision: 8-21-2017

Page: 4 of 4

VII. Substantial Remodel Defined

Substantial Remodel shall mean the renovation of any structure, which combined with any additions to the structure, affects a floor area, which exceeds fifty percent of the existing floor area of the structure. When any structural changes are made in the building, such as walls, columns, beams or girders, floor or ceiling joists and coverings, roof rafters, roof diaphragms, foundations, piles or retaining walls or similar components, the floor area of all rooms affected by such changes shall be included in computing floor areas for purposes of applying this definition. This definition does not apply to the replacement and upgrading of residential roof coverings.

Figure 1

